

# Process Simulation for Energy Consulting

Jan. 2018



한국에너지공단  
KOREA ENERGY AGENCY

# Contents

**L**

**Introduction of Process Simulation**

**L**

**Unit Operation Solving using Aspen HYSYS**

**L**

**Energy consulting example using Aspen HYSYS**

# **I**

## **Introduction of Process Simulation**

**1**

**General**

**2**

**The structure of Process Simulator**

# 1. General

- The advancement in computer-aided process simulation over the past generation has been nothing short of spectacular. Until the last 1970s, it was rare for a graduating chemical engineer to have any experience in using a chemical process simulator. Most material and energy balances were still done by hand by teams of engineers. The rigorous simulation of multistage separation equipment and complicated reactors was generally unheard of, and the design of such equipment was achieved by combination of simplified analysis, shortcut methods, and years of experience.
- In the present day, however, companies of customer now expect ours to be conversant with a wide variety of computer programs, especially a process simulator.
- To some extent, the knowledge base required to simulate successfully a chemical process will depend on the simulation used. Currently there are several process simulators on the market, for example, CHEMCAD, INVENSYS(PRO II, Petrosim, etc.), AspenOne(Aspen Plus\*, HYSYS\*\*, EDR\*\*\*, etc.).
- KEA has introduced HYSYS from 2000, and developed a lot of solutions for processes using simulator till now. Moreover, KEA has many kinds of simulator since introduced total AspenOne package\*\*\*\* in the first 2012s. KEA's simulators are shown [Table].

\* Aspen Plus : the process simulator based aspen database for chemical process especially petroleum, polymer, etc.

\*\* HYSYS : the process simulator based hysys database for chemical process especially gas, refinery plant, etc.


\*\*\* EDR : Exchanger Design and Rating simulator consisted of shell&tube, plate, airfin cooler, etc.

\*\*\*\* total Aspenone package is consisted of all aspen simulators. e.g. utility planner, EDR, Aspen Plus, Polymer etc.

Classification	Simulators	Description	Remarks
Process Modeling	Aspen Plus	Petroleum, Chemical Plant	including polymer
	Aspen HYSYS	Refinery, Gas, Chemical Plant	including upstream
	Aspen Flare	Flare analysis	
	Aspen Utility Planner	Utility optimization	
	Aspen Energy Analyzer	Pinch analysis	
	Aspen Properties	Physical properties analysis	For Plus, HYSYS
	Aspen HYSYS Thermodynamic	Physical properties analysis	For HYSYS
	Aspen Reaction Modeler	Custom Reactor Modeling	
Design and Rating	Aspen EDR	Exchanger Design and Rating	Shell&Tube, Plate, Fired heater Plate Fin, etc
Economic evaluation	Aspen Capital Cost, In-plant, Process economy evaluation	Business Feasibility Estimation	

## ● What is a process simulation?

- Process simulation is a activity describing a real process in the plant using computer software.




## ● Why is a process simulation?

- Simulation using computer software is mainly performed for new plant design, existing plant revamp or expansion, optimal operation, and engineer training.
- Simulation has several advantage like below.
- ① Faster Calculation(More Solutions can be taken at the same time.) ② Accurate Results(rigorous solution can be taken by iteration) ③ Standardization(Simulator has much pure component/binary property Database and thermodynamic methods) ④ Solution of recycle processes(Easy iteration by tearing)

→ **Less Costly than Plant Tests !!**

## 2. The Structure of Process Simulator






# The algorithms for process simulators

- There are basically three types of solution algorithm for process simulators.


## (1) Sequential Modular approach (SM)

: The equations describing the performance of equipment units are grouped together and solved in modules-that is, the process is solved equipment piece by equipment piece.

(a) Solution Sequence Using Sequential Modular Simulator for a process containing No Recycles.



(b) The Use of Tear Streams to solve problems with Recycles Using the Sequential Modular Algorithm





## **(2) Equation Oriented Non-Module approach (EO Method)**

: In the equation solving technique, all the relationships for the process are written out together and then the resulting matrix of nonlinear simultaneous equations is solved to yield the solution. This technique is very efficient in term of computation time but requires a lot of time set up and is unwieldy.

## **(3) Combined method between SM and EO**

The simultaneous modular approach, which combines the modularizing of the equations relating to specific equipment with the efficient solution algorithms for the simultaneous equation solving techniques.

\* Of these three types, the sequential modular algorithm is by far the most widely used. In the sequential modular method, each piece of equipment is solved in sequence, starting with the first, followed by second, and so on. It is assumed that all input information required to solve each piece of equipment. Therefore, the output from a given piece of equipment, along with specific information on the equipment, becomes the input to the next piece of equipment in the process. Clearly, for a process without recycle streams, this method requires only one flowsheet iteration to get a converged solution.



## **Unit Operation Solving using Aspen HYSYS**

- 1 Pressure change Equipments**
- 2 Heat Exchangers**
- 3 Distillation Column**

# 1. Pressure Change Equipments


## ● Pumps

- Problem : “A” Plant is required 25 °C cooling water to cool down process stream. And, you should try to design the cooling water pump The design value of a pump is like below. Calculate the pump power consumed using Aspen HYSYS.

\* Design value; Flow Rate: 30,000 m<sup>3</sup>/h, adiabatic efficiency: 75 %(HYSYS Default), Differential pressure: 5 bar

- Solution: Power Consumed = 5504 kW (see below PFD converged by Aspen HYSYS)

Temperature	25.00	C
Pressure	0.0000	bar_g
Std Ideal Liq Vol Flow	3.000e+004	m3/h



Temperature	25.04	C
Pressure	5.000	bar_g


Power	5504	kW
-------	------	----

## ● Compressor/Blower/Fan

- Problem : An Air Blower is operated according to the Performance Curve below with 3000 rpm. The Blower leads to less air flow than rated output and causes excessive pressure loss as shown in the figure below. The introduction of inverters is under review to save power. Calculate appropriate rpm and power savings. (The inlet air is assumed at 25 oC and 1 atm)

Flow Rate (CMM)	Head (mm-Air)	Efficiency (%)
145	420,000	30
290	419,167	45
435	391,667	62
580	379,167	71
725	354,167	75
870	298,333	82
1,015	295,833	85
1,192	254,167	82
1,305	212,500	80

[FDF Performance Table]



[FDF Performance Curve]

- Solution : The RPM is able to reduce till 2777, and 9.93 kW would be saved from 61.26 kW to 51.33 kW.

### Base Case

Temperature	25.00	C
Pressure	-4.268e-004	cmH2O(4C)_g
Molar Flow	4.786e+004	Nm3/h(gas)

1

K-100

3000 rpm

Q-100

Power 61.26 kW

2

Temperature	28.60	C
Pressure	35.75	cmH2O(4C)_g
Molar Flow	4.786e+004	Nm3/h(gas)

### Project Case

Temperature	25.00	C
Pressure	-4.268e-004	cmH2O(4C)_g
Molar Flow	4.786e+004	Nm3/h(gas)

1-2

K-100-2

2777 rpm

Q-100-2

Power 51.33 kW

2-2

Temperature	28.02	C
Pressure	30.46	cmH2O(4C)_g
Molar Flow	4.786e+004	Nm3/h(gas)

ADJ-1

## 2. Heat Exchangers


### ● Fired Exchanger

- Problem : “B” Plant have a boiler to generate steam of 15 barg. Natural gas consisted of 85% Methane, 5% Ethane and 10% propane is using for fuel, and ambient air is supplied to combust through the an air preheater to fired box as 190 °C. BFW is supplied to the boiler as 180 °C. The temperature of exhaust gas is 550 °C.

When fuel gas consumed 5,392 kg/h, calculate steam generated rate using Aspen HYSYS.

(at O<sub>2</sub> mol% of flue gas = 5.0, flue gas temperature = 150 °C, Blow Down rate = 5 t/h)

-Solution : Steam produced 100.3 t/h



### ● Shell and tube heat exchanger

- Problem : Raw water 15 t/h (30 °C, 5 kg/cm<sup>2</sup>g) is supplied to make up boiler feed water. You guess that energy loss is occurred in the boiler feed water system since the low water temperature. So you would heat up the raw water by installing an heat exchanger recovered waste heat. Your company have one existing heat exchanger tabled below. How much does the water heat up possible using the heat exchanger. (The waste heat source like below.)
- Moreover, if you install a new heat exchanger and heat the raw water up to 90 °C, how much does the exchanger be sized?


Existing Heat Exchanger Specification	Waste Heat Source
TEMA Type : H-BEM Size : 585 mmID × 1,829 mmTL, 35.7 m <sup>2</sup> Baffle Central Spacing : 885 mm Tube ID : 1 inch, Thickness : 2.11mm Tube arrangement : 30 Angle Material : Stainless (SUS316) Fouling resistance : 0.0004 m <sup>2</sup> -h-C/kcal Allowable pressure drop : 11 kPa (Shell Side) 50 kPa (Tube Side)	Waste Heat Name : Vent Vapor from flash vessel Fluid Composition : 100% H <sub>2</sub> O Condition : atmospheric saturated steam Flow rate : 2,500 kg/hr

- Solution : The solution can be gotten using process modeling simulator like Aspen Plus or HYSYS integrated Aspen EDR. The solution is next page.




- Solution : In case of using the existing exchanger, 15 t/h raw water of 30 °C will be heat up to 65.45 °C recovering 0.55 Gcal/h from waste heat, however, in case of a new exchanger installation and heating up to 90 °C, the waste heat recovered is 0.94 Gcal/h.

Existing		
Duty	549.1	Mkcal/h
Tube Inlet Temperature	30.00	C
Tube Outlet Temperature	65.45	C
Shell Inlet Temperature	99.96	C
Shell Outlet Temperature	99.45	C




NEW		
Duty	940.2	Mkcal/h
Tube Inlet Temperature	30.00	C
Tube Outlet Temperature	90.52	C
Shell Inlet Temperature	99.96	C
Shell Outlet Temperature	98.86	C



Material Streams									
		Raw Water	Heated Raw Water	Vent Vapor	3	Raw Water-2	Heated Raw Water-2	Vent Vapor-2	3-2
Vapour Fraction		0.0000	0.0000	1.0000	0.5969	0.0000	0.0000	1.0000	0.3105
Temperature	C	30.00	65.45	99.96	99.45	30.00	90.52	99.96	98.86
Pressure	kg/cm2_g	5.000	4.970	2.022e-007	-1.871e-002	5.000	4.570	2.022e-007	-4.003e-002
Molar Flow	kgmole/h	832.6	832.6	138.8	138.8	832.6	832.6	138.8	138.8
Mass Flow	tonne/h	15.00	15.00	2.500	2.500	15.00	15.00	2.500	2.500
Liquid Volume Flow	m3/h	15.03	15.03	2.505	2.505	15.03	15.03	2.505	2.505
Heat Flow	Mkcal/h	-5.688e+004	-5.633e+004	-7939	-8488	-5.688e+004	-5.594e+004	-7939	-8879

### Heat Exchanger Specification Sheet

1	Company:									
2	Location:									
3	Service of Unit:					Our Reference:				
4	Item No.:					Your Reference:				
5	Date:		Rev No.:			Job No.:				
6	Size: 438 - 5850		mm		Type: BEM	Horizontal		Connected in: 1 parallel 1 series		
7	Surf/unit(eff.)		40 m²		Shells/unit 1		Surf/shell(eff.) 40 m²			
8	<b>PERFORMANCE OF ONE UNIT</b>									
9	Fluid allocation				Shell Side			Tube Side		
10	Fluid name				Vent Vapor-2->3-2			Raw Water-2->Heated Raw Water-2		
11	Fluid quantity, Total				kg/h 2500			15000		
12	Vapor (In/Out)				kg/h 2500 776			0 0		
13	Liquid				kg/h 0 1724			15000 15000		
14	Noncondensable				kg/h 0 0			0 0		
15										
16	Temperature (In/Out)				°C 99.96 98.86			30 90.52		
17	Dew / Bubble point				°C 99.96 99.96			158.32 158.32		
18	Density Vapor/Liquid				kg/m³ 0.59 / 0.57 / 949.38			/ 1003.72 / 955.99		
19	Viscosity				cp 0.0121 / 0.0121 / 0.2843			/ 0.7972 / 0.3095		
20	Molecular wt, Vap				18.02 18.02					
21	Molecular wt, NC									
22	Specific heat				kJ/(kg-K) 1.907 / 1.906 / 4.393			/ 4.313 / 4.376		
23	Thermal conductivity				W/(m-K) 0.0245 / 0.0244 / 0.6799			/ 0.6182 / 0.6762		
24	Latent heat				kJ/kg 2276.4 2279.4					
25	Pressure (abs)				kPa 101.325 97.399			591.658 549.529		
26	Velocity (Mean/Max)				m/s 10.26 / 35.37			1.22 / 1.54		
27	Pressure drop, allow./calc.				kPa 11 3.926			50.014 42.128		
28	Fouling resistance (min)				m²-K/W 0.00034			0.00034 0.00041 Ao based		
29	Heat exchanged		1092.7 kW		MTD (corrected)			29.22 °C		
30	Transfer rate, Service		934.9 Dirty 935		Clean		3187		W/(m²-K)	
31	<b>CONSTRUCTION OF ONE SHELL</b>							<b>Sketch</b>		
32					Shell Side			Tube Side		
33	Design/Vacuum/test pressure				kPa 300 / /			700 / /		
34	Design temperature				°C 135			125		
35	Number passes per shell				1			8		
36	Corrosion allowance				mm 3.18			3.18		
37	Connections		In mm		1 202.72 / -			1 52.5 / -		
38	Size/Rating		Out		1 154.05 / -			1 52.5 / -		
39	ID		Intermediate		/ -			/ -		



### 3. Distillation Column

#### ● Distillation Column


- Problem : Light composition in the process stream that is composed of C4-C8 is fully refluxed with vapor in the distillation column and the composition containing C6 and greater components is being produced at the bottom of the column. At this time, n-Pentane is controlled at 0.1wt% at the bottom of the column and n-Hexane controlled on-spec at 0.05 wt% at the top of the column. Hence, a feed/bottom heat exchanger is to reduce heat duty of the distillation column reboiler by increasing feed temperature.

Set up the simulation model about this distillation column.

Feed Stream Composition	Stream Condition	Distillation Column Data
n-Butane 5 wt% n-Pentane 10 wt% n-Hexane 60 wt% n-Heptane 15 wt% n-Octane 10 wt%	Pressure: 4 kg/cm <sup>2</sup> g Temperature: 50°C Flow: 50 ton/h	No. of Stage 48 Valve Tray Feed Stage: 28 stage Condenser Pressure: 3.4 kg/cm <sup>2</sup> g Condenser DP : 0.1 bar Column Bottom Pressure: 3.8 kg/cm <sup>2</sup> g Reboiler DP : 0.15 bar

## ● Distillation Column

### - Solution



Material Streams								
		Reflux	To Condenser	Boilup	To Reboiler	OH	BOT	Feed
Vapour Fraction		0.0000	1.0000	1.0000	0.0000	1.0000	0.0000	0.0000
Temperature	C	75.79	80.97	136.8	132.5	75.79	136.8	50.00
Pressure	kg/cm2_g	3.400	3.502	3.800	3.647	3.400	3.800	4.000
Molar Flow	kgmole/h	275.6	387.3	714.1	1181	111.8	467.3	579.0
Mass Flow	kg/h	1.910e+004	2.656e+004	6.309e+004	1.056e+005	7461	4.254e+004	5.000e+004
Liquid Volume Flow	m3/h	30.74	42.91	94.62	158.0	12.16	63.34	75.51
Heat Flow	Mkcal/h	-1.049e+004	-1.255e+004	-2.616e+004	-5.098e+004	-3572	-2.033e+004	-2.687e+004




## **Energy consulting example using Aspen HYSYS**

- 1 Gasoil stripper**
- 2 Waste heat boiler**
- 3 Phenol Process**

# 1. GasOil stripper

## ● Base Case PFD

- The bottom temperature of 'GasOil Splitter' is 333 °C . It should be cooled before storage tank. In the heat recovery process, the feed stream(VR Feed) is heated up to 210 °C and middle pressure steam is generated at the steam generator.
- Energy Loss Point : The energy loss is occurred at the 'Tempered Water Cooler'. The steam temperature before TW Cooler is 150 °C . It is enough to heat other steam up to 120~130 °C (In this sample case, target approach temperature is 25 °C).




## ● Process Modeling for base case using Aspen HYSYS

### - Process Modeling Condition

Boiler Feed Water : 165°C, 3.5kg/cm<sup>2</sup>.g

Middle Pressure Steam : 193°C, 12.5kg/cm<sup>2</sup>.g


Stripper Bottom Feed, VR Feed, Naphtha and Gas Oil steams are generated by process simulator(Aspen HYSYS Oil manager)(based on lab distillation data.)






## ● Project Case PFD


- Energy Saving Target : The 'GasOil stripper feed' is heated by low pressure steam. If it heated by waste heat, it can save the LP steam(definitely, it can save fuel gas or oil at the steam boiler
- Run-down stream have enough heat amount to heat up this feed stream. In this case, we set the target heat up temperature 125°C. It is typical approach temperature temperature in refinery heat exchanger network design.
- The expected effect of applying project case is saving LP steam about 2.3 ton/h and increasing MP Steam generation about 0.6 ton/h.



## ● Process Modeling for project case using Aspen HYSYS




## ● New heat exchanger design for project case using Aspen EDR


Size: 600 - 6000 mm Type: AES Horizontal Connected in: 1 parallel 2 series						CONSTRUCTION OF ONE SHELL										Sketch											
Surf/unit(eff.)		206 m²		Shells/unit 2		Surf/shell(eff.)		103 m²																			
PERFORMANCE OF ONE UNIT										Design/Vacuum/test pressure kPa												2400 / /		2500 / /			
Fluid allocation				Shell Side				Tube Side				Design temperature °C										190		165			
Fluid name				14->18-2				16-2->GasOil-2				Number passes per shell										1		4			
Fluid quantity, Total				kg/h 62277				42780				Corrosion allowance mm										3.18		3.18			
Vapor (In/Out)				kg/h 0		0		0		0		Connections				In mm		1 154.05 / -				1 77.93 / -					
Liquid				kg/h 62277		62277		42780		42780		Size/Rating				Out		1 154.05 / -				1 90.12 / -					
Noncondensable				kg/h 0		0		0		0		ID				Intermediate		1 154.05 / -				1 77.93 / -					
										Tube No. 226 OD 25.4 TksAverage 2.11 mm Length 6000 mm Pitch 31.75 mm																	
Temperature (In/Out)				°C 150.15		103.46		50.7		125.57		Tube type Plain				#/m Material Carbon Steel				Tube pattern 30							
Dew / Bubble point				°C								Shell Carbon Steel				ID 600 OD 620 mm				Shell cover Carbon Steel							
Density Vapor/Liquid				kg/m³		/ 848.99		/ 880.82		/ 833.29		/ 780.47		Channel or bonnet Carbon Steel				Channel cover Carbon Steel									
Viscosity				cp		/ 7.87		/ 21.7149		/ 2.1183		/ 0.6702		Tubesheet-stationary Carbon Steel				-				Tubesheet-floating Carbon Steel					
Molecular wt, Vap												Floating head cover Carbon Steel								Impingement protection None							
Molecular wt, NC												Baffle-cross Carbon Steel				Type Single segmental		Cut(%d) 29.37		HoriSpacing: c/c 235 mm							
Specific heat				kJ/(kg-K)		/ 2.36		/ 2.176		/ 1.898		/ 2.222		Baffle-long -				Seal Type				Inlet 388.71 mm					
Thermal conductivity				W/(m-K)		/ 0.1187		/ 0.1252		/ 0.1179		/ 0.1088		Supports-tube U-bend				0				Type					
Latent heat				kJ/kg										Bypass seal				Tube-tubesheet joint				Expanded only (2 grooves)(App.A 'i')					
Pressure (abs)				kPa		2160.722		2115.983		2258.789		2230.831		Expansion joint -				Type None									
Velocity (Mean/Max)				m/s		0.45 / 0.58		0.74 / 0.77						RhoV2-Inlet nozzle 1015				Bundle entrance 122		Bundle exit 117		kg/(m-s²)					
Pressure drop, allow./calc.				kPa		50		44.739		50		27.957		Gaskets - Shell side				Flat Metal Jacket Fibe				Tube side		Flat Metal Jacket Fibe			
Fouling resistance (min)				m²-K/W		0		0		0		Ao based		Floating head				Flat Metal Jacket Fibe									
Heat exchanged				1833. tW		MTD (corrected)		31.71 °C		Code requirements										ASME Code Sec VIII Div 1				TEMA class R - refinery service			
Transfer rate, Service				280 Dirty		280.6		Clean		280.6		W/(m²-K)		Weight/Shell				4270.4		Filled with water 6016.5		Bundle 2033.4		kg			

## 2. Waste heat boiler Heat


### ● Base Case PFD




- **Elevation drawing of WHB**



- Process Modeling for base case using Aspen HYSYS



## ● Project Case PFD




(Unit : MMkcal/h, t/h)

Heater Section	Design	As is	To be	Difference
Super Heater	1.14	0.64	0.65	0.01
Steam Generator	2.69	2.00	2.32	0.32
Economizer	0.32	0.30	0.19	-0.11
<b>Total</b>	<b>4.14</b>	<b>2.94</b>	<b>3.16</b>	<b>0.22</b>
MP Steam	10.2(393°C)	9.6	10.1	0.5




- Process Modeling for project case using Aspen HYSYS




# 3. Phenol Process


## ● Base Case PFD




- **Process Modeling for base case using Aspen HYSYS**



## ● Project Case PFD



## ● Process Modeling for project case using Aspen HYSYS



# Thank you!



한국에너지공단  
KOREA ENERGY AGENCY