

Energy Audit Procedure & Practices

17 JAN 2018

KOREA ENERGY AGENCY
Mr. Kyung-soon Park



CONTENTS

- I. Introduction of Energy Audit Act**
- II. Energy Audit Procedure**
- III. Energy Audit Practices**




I Introduction of Energy Audit Act



Why Energy Audit ?

Energy Audit will guide you to sustainable development





Korea adopted Mandatory Energy Audit Scheme to Respond UNFCCC and Continuous Rising of Oil Prices in 2007

Continuous Rising Energy Consumption & Oil Prices


Energy Audit is the Best Solution

UNFCCC* Implementation Reduction GHG Needed

Energy Environment


Dependence on energy imports

Unit : %




Energy imports

Unit : Billion \$



New Effective Scheme Needed

Korea Climate Change




* UNFCCC : United Nation Framework Convention on Climate Change



KEA is the Operational Entity of Energy Audit Scheme

Workflow of the Energy Audit Scheme



1. Notice

KEA notifies energy-intensive companies that are subjected to energy audit

2. Application

A company subject to an energy audit must apply to an energy audit company, 3 months before the end of its audit period

3. Energy Audit contract

Contracting between EIC and EAC

4. Conducting Field Energy Audit

EAC conduct on-site audit according to the contract

5. Documentation and Report

EAC submits a report for the results of energy audit to EIC and KEMCO

※ Post Audit Activities

- Assess the Report, Implementation of support



Summary of Energy Audit Scheme

1. Stakeholders of Energy Audit Scheme :

- MOTIE(Ministry of Trade, Industry and Energy) : General Management Agency of Energy Audit Scheme
- KEA(Korea Energy Agency) : Operational Entity of Energy Audit Scheme
- EIC(Energy Intensive Company) : Target to be audited of energy
- EAC(Energy Audit Company) : There are 2 types of energy audit company, and 93 companies are designated from MOTIE by 2013(Type1 : conduct all kind of workplace, Type2 : conduct workplace that use less than 420TJ of energy consumption per year)

2. Target : Energy intensive companies whose annual energy consumption is over 84TJ

3. Energy Audit Cycle : Energy audit target company has to take energy audit every 5 years

6. Energy Audit Days and Personnel : It depends on the amount of annual energy consumption, usually put 3~4 people and 10~50 days into on-site energy audit (except report writing days)

7. Energy Audit Fee : Determined according to the number of audit days and personnel

- If energy consumptions are 4,200 TJ, then costs are about 115,000USD, but costs can be adjusted by contract

8. Energy Audit Postponing : If company meets a natural disaster, bankruptcy and shut-down, plan to move etc, company can postpone up to 12 months

9. Energy audit Exemption and Extension : If it receives Presidential award or Prime Minister's award, energy audit can be exempted one cycle, and If it receives Ministerial award, energy audit cycle can be extended three years

10. Subsidies for Small and Medium sized Enterprises (SMEs) : Support energy audit fee up to 70%


11. Fines : If not take energy audit within the deadline, fines are imposed by every violation

- One time : 10 Million Won, Two times or more : 20 Million Won per violation




Korea Secured 18,295 TJ of Energy Saving Potential in 2013

Energy Audit Activities in 2013



※ ESCO : Energy Service Company, Instead of energy users, ESCOs invest in energy saving facilities for energy conservation and reducing green house gas

ENERGY AUDIT EVOLUTION WITH KEA



2011

Development to Premium Energy Audit with Process simulation

- Pinch Analysis, Column Targeting , etc.

2009

CDM/EnMS linked Customized Energy Audit

- Energy Audit specialized in Petroleum Refinery, Steel Industry

2007

Establish Mandatory Energy Audit Act

- for energy intensive companies 10,000 toe above

Expanding the use of Process Simulation Software

(AspenOne, Exchanger, etc)

1998

~
2006

Introduced of Software Customized in Power Plant (Thermoflex)

- Conduct Energy Audit in lots of power plants

1997

Development of software energy audit (Hypotech HYSYS)

- Energy Audit Demand in Chemical Engineering and Metal Industry Increased

1994

Conducted Electricity Demand Side Management Survey, built Heat Balancing Standard (KS) of a boiler and program

- Built Textile (Tenter), Food (Concentrator) related Heat Balance Excel Program

1989

Site Survey in each Industry (100 companies except in-depth management companies)

- Measured Facility based operating efficiency and developed methods to reduce energy intensity

1987

In-dept Energy Audit in energy intensive companies (Cement, Steel Furnaces), and ships

1985

General Energy Audit in Industries (Bus Audit, Thermal Image TVS Audit), Energy Audit in fired equipment - Composed Computer based TVS report, Introduced Heat Balance Excel Program

1980

~
1984

In-Depth Energy Audit in Industry, Building (Heat, Electricity), Established Field-based Specialized Energy Audit Team

- Focused on Energy Audit in Combustion Facility, Utility System

(Boiler flue gas Heat Recovery, Adjust Air fuel ratio, etc.)

1974

Appointed to Heat Management and Audit Institution As Korea Energy Management Engineering Association has established, Developed Energy Audit Methods (Benchmarking Developed Countries)



KEA's Energy Audit Purpose is to upgrade customer's energy conditions.

Enhancing Competitive Positions and Contribute to Climate Change mitigation




II *Energy Audit Procedure*



To Improve Energy Efficiency, Decrease Energy Costs and Reduce GHG, We conduct Audit by 10 procedures

Energy Audit Procedure

To Improve Efficiency,
Decrease **Costs** and
Reduce GHG



Main Deliverables

- Efficiency & Intensity of Energy System
- Description of EMOs and Implementation Methods
- Estimation of Energy Savings & GHG reduction potential
- Economic Analysis (NPV, IRR, etc)
- M & V Methods for post-implementation assessment

* EMOs : Energy Management Opportunities

ENERGY AUDIT PROCEDURES



GENERAL PROCEDURES OF ENERGY AUDIT (AT A GLANCE)

Start meeting



- Kick-Off with officials

Data collections






- Taking PFD, P&ID, Equipment list, Performance curves and so on for energy analysis

Measurements





- Operating condition check if necessary data is not enough

Analysis of Base and Improvement case



- Energy performance analysis using collected and measured data
- Energy loss check through pinch analysis
- Base simulation model construction using Aspen tools and so on
- Creating Energy Improvement opportunities
- Project simulation model construction using Aspen tools and so on

Design and Economics



- Design of new equipments to be installed
- Investment cost estimation
- Economic analysis by cash flow


Presentation



- The final review meeting for energy audit results


ENERGY AUDIT PROCEDURES

Understanding Procedures (Using PFD, P&ID)




ENERGY AUDIT PROCEDURES

Excavating Themes by Function Analysis



ENERGY AUDIT PROCEDURES

Theme Excavation by Loss Structure Analysis



ENERGY AUDIT PROCEDURES

Find Improvement Idea for Excavation Theme

Find Possible Improvement Idea

Bring Up Ideas



Possible to Execute
60


Gathering Information

Theme
100

Expert Advise

Impossible to Execute
40

Simulation




-Technical Problem
- Improvement Effect
and Invest Payability
Problem

ENERGY AUDIT PROCEDURES

Find out Possible Solution through mutual discussion

Review Possibility
for Ideas

Mutual Discussion



Risk Analysis and
backup measures for
Most suitable Solution

Possible Solution(1)


Possible Solution(2)

Possible Solution(3)

Possible Solutions

EQUIPMENTS FOR ENERGY AUDIT

- Infrared Camera



- A device checking the heat loss such as insulation performance and exothermic of electric

- Flue Gas Analyzer



- A device checking the combustion performance and temperature of flue gas

EQUIPMENTS FOR ENERGY AUDIT

- Multi Temperature Humidity Meter



- A device measuring temperature or humidity

- Ultrasonic Flow Meter



- A device measuring flow rate in pipe

- Power Measurement Device



- A device measuring power consumption

- Continuous Power Meter




- A device measuring power consumption

Energy Audit using Computer Software

■ KEA's Audit with World Class Software and High Tech Devices

Integrated Solution with Rigorous Software and High-tech Devices



Energy Audit Practices

Energy Audit Visualizes Current Situation



Why is Data Analysis So Important?

- You can see the present and the future condition through Instrument Panel in the Pilot seat





Why is Data Analysis So Important?

- CEO should be able to see company's present and future condition in Management Cockpit





Why is Data Analysis So Important?

What is Data?

Phenomenon of Objects expressed with numbers (Digits)

What is the hidden meaning of Data?

According to Prof. Sung Hyun Park of Seoul National University,

- All data is information, meaning it is just as dead if it is not refined and analyzed.
- Data is NOT an Inference.
- What People look for is an Inference, not Data.
- Even after analyzed, only few Data can obtain lives.
- There is no Bad Data, only data with Bad Intentions exist.



Why is Data Analysis So Important?


◆ Let's Think about it... Importance of Measurement

- ◆ We do not know the fact that we do not know.
- ◆ If we cannot express what we know through accurate measurement, then we do not know enough.
- ◆ If we do not know enough about them, we cannot manage them.
- ◆ If we cannot manage them, the result depends on luck.
- ◆ If we do not know about them, we cannot take measures against them.
- ◆ If we can take measures against them, the risk can be managed.
- ◆ But, if we know about them and not take measures, we deserve the damage inflicted by them



Why is Data Analysis So Important?

Can a single sample represent the whole group?




If a sample not representing whole group is extracted and made judgment from it, You will make judgment error just like blind men touching elephant.




Measurement Cases: Duct Automatic Damper breakdown (Malfunction)

◆ Lack of Hot-air due to Damper breakdown



◆ Normal supply of Hot air after Damper Improvement





Measurement Case: Equal and Efficient Heating System Management

- **Problems**

- Heating Inequality occurs when Residence with sufficient heating opens window, and insufficient residence has complains for not provided enough heat.
- Complains for taxed with same amount even if heating inequality occurs.





Measurement Case: Equal and Efficient Heating System Management


Infrared Thermal Imaging Photo



Residence 1




Residence 2




Residence 3




Residence 4




Residence 5



Residence 6



Residence 10




Residence 11



Equal and Efficient Heating System Management


Operating status
(Residence 11)





Equal and Efficient Heating System Management


Operating Status
(Residence 6)





Equal and Efficient Heating System Management

Operating Status
(Residence 3)






-
- The diagram illustrates a heating system with 11 blocks and three heat exchangers. The system is configured as follows:
- Heat Exchangers:**
 - 420 Mcal/h (Yellow):** Located at the top left, it receives a blue supply line at 40.0°C and a red return line at 51.5°C . Its output is a blue line at 35.3°C that feeds into the 800 Mcal/h exchanger.
 - 800 Mcal/h (Cyan):** Receives the 35.3°C blue line and a red line at 51.0°C from the 5 Block. Its output is a blue line at 34.4°C that feeds into the 700 Mcal/h exchanger.
 - 700 Mcal/h (Purple):** Receives the 34.4°C blue line and a red line at 56.9°C from the 4 Block. Its output is a blue line that joins the main return line.
 - Blocks:**
 - 10 Block (Cyan):** Receives a red line from the 420 Mcal/h exchanger and a red line from the 5 Block. Its output is a red line that joins the main return line.
 - 6 Block (Yellow):** Receives a red line from the 10 Block and a red line from the 11 Block. Its output is a blue line that joins the main return line.
 - 11 Block (Yellow):** Receives a red line from the 6 Block and a red line from the 1 Block. Its output is a blue line that joins the main return line.
 - 5 Block (Cyan):** Receives a red line at 51.0°C from the 800 Mcal/h exchanger. Its output is a blue line that joins the main return line.
 - 4 Block (Cyan):** Receives a red line at 56.9°C from the 700 Mcal/h exchanger. Its output is a red line that joins the main return line.
 - 2 Block (Purple):** Receives a red line from the 5 Block. Its output is a blue line that joins the main return line.
 - 1 Block (Purple):** Receives a red line from the 2 Block. Its output is a blue line that joins the main return line.
 - 8 Block (Purple):** Receives a red line from the 4 Block. Its output is a blue line that joins the main return line.
 - 7 Block (Purple):** Receives a red line from the 700 Mcal/h exchanger. Its output is a blue line that joins the main return line.
 - 3 Block (Purple):** Receives a red line from the 4 Block. Its output is a blue line that joins the main return line.
- The system uses a red line for heating medium flow and a blue line for return flow. The flow is driven by three pumps, each represented by a circle with a triangle inside. The return line for all blocks and exchangers joins a single blue line that exits the bottom of the diagram.



Equal and Efficient Heating System Management


● Measurement and Analysis (420M heat exchanger (Residence 6, 11))





Equal and Efficient Heating System Management


- Measurement and Analysis (700M heat exchanger (Residence 1, 2, 3, 7, 8))





Equal and Efficient Heating System Management


- Measurement and Analysis (800M heat exchanger (Residence 4, 5, 10))





Equal and Efficient Heating System Management


● Measurement and Analysis (Residence 11 Header Heating Water Input and Output Temperature)





Equal and Efficient Heating System Management


● Measurement and Analysis (Residence 6 Header Heating Water Input and Output Temperature)





Equal and Efficient Heating System Management

● Measurement and Analysis (Residence 3 Header Heating Water Input and Output Temperature)





Equal and Efficient Heating System Management

● Measurement and Analysis

- Residence 6 and 11 have multiple complaints due to insufficient heating provided
- Thermal Imaging Results can verify the complaints
- Insufficient Calories provided in 420M heat exchanger, provides heat to residence 6 and 11

Heat exchanger Capacity (Mcal/h)		Residence 6, 11		Residence 1,2,3,7,8		Residence 4,5,10	
		420		700		800	
Heating Area (m ²)	Possible Supply Calories per Area (kcal/m ²)	4132	102	8151	86	7821	102
Heating Water Circulation (ℓ /h)		29,900		42,800		51,600	
Supply/Return Temperature (°C)		51.5	40.0	56.9	34.4	51.0	35.3
Heating water Supply Calories (Mcal/h)		343		961		814	
Actual Supplying Calories per Calories (kcal/m ²)		83		118		104	



Equal and Efficient Heating System Management

- Operating Status
 - Residence 6 and 11 are set to shut down steam supply in return temperature above 37°C through electric valve.
 - Because of low absorption rate of residence 6 and 11, 30~50 minutes after initiating return temperature of the heating water remains high (45°C).
 - Because return temperature remains high, **steam supply is frequently shut down**, leaving insufficient calories for heat exchanger.
 - Because steam supply pressure is 0.4~1.0 kg/cm², **lower than Design Value 2 kg/cm², steam supply is not adequate.**



Equal and Efficient Heating System Management

- Operating Status – Current Steam supply pressure of 0.4 ~ 1.0 kg/cm² cannot provide enough steam in heat exchanger -> Insufficient supply Calories

	Required Steam amount in heat exchanger (kg/h)			Possible Steam amount in Supply Pipes (kg/h)		
	0.7kg/cm ² g	1kg/cm ² g	2kg/cm ² g	0.7kg/cm ² g	1kg/cm ² g	2kg/cm ² g
42 (Mcal/h)	799	794	813	716	730	1,215
70 (Mcal/h)	1,331	1,323	1,354	1,145	1,160	1,755
80 (Mcal/h)	1,521	1512	1,548	1,145	1,160	1,755




Equal and Efficient Heating System Management

- Improvement Ideas
 - Continuous operation of pump until return water temperature of residence 6 and 11 is 35°C.
 - Regulator is set so that Intermediate machine room **steam supply pressure remains 2 kg/cm^2**
 - If current steam supply pressure is left unchanged, enlarging heat exchanger capacity does not give effective heating water supply calories.


Rationalizing EPS Reactor Heating/Cooling System

◇ Operating Status




Picture explains heating process, and EA-1201 Front and Back valves are closed in cooling process


◇ **Heating Load Profile in 1st temperature rise of reactor
(0min~ 65.3min)**




◇ **Heating Load Profile in 2nd temperature rise of reactor
(311.7 min~ 388min)**




◇ **CWS , CWR Temperature Profile When Reactor is Internally Cooling(428~478min)**



◇ **CWS , CWR Temperature Profile When Reactor is Internally Cooling(938~1,030min)**




◆ Improvement Ideas



Retrieving Boiler Emission Gas Heat

◆ System Operating Status



Air leak % : 38% (Ljungstrom model GAH)

Retrieving Boiler Emission Gas Heat


◆ Focus Point

- obsolete equipment of GAH and structural leak gives decreased heat exchanger capacity
- Retrieving most Emission Gas heat can be achieved through switching old one to Economizer, which is without air leak.

◆ Improvement Idea Review

- Switch to Economizer, one without air leak.
- Additional Installation of corrosion resistance heat exchanger Behind Electric Precipitator (EP) to retrieve emission Gas heat (combustion air warm up heating source)

Ljungstrom model GAH Structure



Typical air preheater - design AGT

- ① Combined cleaning device for blowing with steam or compressed air and washing with water
- ② Rotor Drives
- ③ Axial Seal - adjustable during boiler operation
- ④ Radial Seal - adjustable during boiler operation
- ⑤ Guide Bearing
- ⑥ Rotor
- ⑦ Heating Elements in Containers
- ⑧ Hot Layer (Material: steel)
- ⑨ Cold Layer (Material: steel, "Corten" or enameled steel)
- ⑩ Intermediate Layer (Material: steel)
- ⑪ Pin Rack



◇ Leak Cases

- Carry-in Leakage : As Rotor rotates, fluid left in the rotor is mixed in with other fluids in the rotor, causing leakage (**Entertained Leakage**)
- Direct Leakage : Because of pressure difference between two Heat exchangeable fluids, High pressured fluid is inserted into low pressure liquids through seals located between rotor and outside surface casing (70% ~80% of leak cases)

◇ Leak Reasons


- Disparity between Structural temperature conditions and actual operating condition causes over extended gap between each seals under Hot condition.
- ✓ Difference Structural heat modification and actual heat modification causes wider gap
- ✓ Corrosion of Seal plate and surface area, heat modification, abrasion, Seal plate loss, causes wider gap

Ljungstrom model GAH AIR LEAK proportion (Structure)



Leakage (%)

Air preheater leakage vs load factor





◆ Issues of increased GAH air leak

- Rise of emission heat loss (Weaken GAH Cooling End Temperature Management)
- Increasing Load of F.D FAN also increases electric usage load.
- Among Heated air from SAH(Steam Air Heater), Leakage air is not properly used, and emitted outside (Increased steam load)

Thank you for Your participation.

17 JAN 2018

KOREA ENERGY AGENCY
Mr. Kyung-soon Park

